



Government Of West Bengal
Office Of The Divisional Fire Officer, Jalpaiguri
West Bengal Fire & Emergency Services
Jalpaiguri Fire Station, Race Course Para,
P.O. & P.S. :- Jalpaiguri, Pin:- 735101

Memo no.: WBFES/JD/FP/407/17

Date: 02-03-2024

From:
Divisional Fire Officer, Jalpaiguri
West Bengal Fire & Emergency Services

To: Caesar School
P.O, P.S-MALBAZAR, DIST-JALPAIGURI

Sub: Renewal of fire safety certificate of an existing G+2 storied school building under group Educational in the premises of CAESER SCHOOL PRAMOD NAGAR COLONY, MALBAZAR, JALPAIGURI.

This is in reference to your application no. 0125191247900025 dated 15-02-2024 regarding the Renewal of fire safety certificate of an existing G+2 storied school building under group Educational in the premises of CAESER SCHOOL PRAMOD NAGAR COLONY, MALBAZAR, JALPAIGURI.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.



Recommendation:

- 1) All extinguishers should be tested and refilled in every year and certificate is to be pasted in the body of the extinguishers.
- 2) Electric line/Meter box should be checked with register electrician and proper maintain should be made, if necessary.
- 3) Always main gate is to be made free and should engage a person for maintain of the gate.
- 4) Always under ground and over head reservoir should be filled up with water. A stand by pump is to be activated and the persons for operating pump should be engaged.
- 5) Good house keeping should always be maintained.
- 6) All the staff members should have the knowledge to operate the fire extinguishers accordingly and they should always be aware of installed fire safety measure as incorporated in the building.
- 7) Fire safety certificate shall be renewed in every 3(Three) years comprising safety installations are in working condition.